DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 9A-9-A-103
DATE: 9-7-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: JERRY HAYES
ADDRESS: RT. 8 Box 293-A
STATESVILLE NC 28677
OWNER / AGENT: PHONE: 872-0442
APPLICATION DATE: 8-30-95 DATE EVALUATED 9-5/7-95
PROPOSED FACILITY: 3BR MH
PROPERTY SIZE: 4 ACRES±
LOCATION OF SITE: I-77N, TR NC901, TL EAGLE MILLS, TL TRIPLETT, TR CORNWALL, AT CHA ON LEFT
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	FS	0-16+	SILTY SAPROLITE CUT SLOPE					.1942 Wetness Cond. S .1943 Depth/.1956 Sapr. 4 .1944 Restrictive Hori. - .1948 Profile Class. 4 Profile LTAR -
2	FS	0-10	SILTY/MICA SAPROLITE CUT					.1942 Wetness Cond. - .1943 Depth/.1956 Sapr. -4 .1944 Restrictive Hori. - .1948 Profile Class. 4 Profile LTAR -
3	L 4%	0-4 4-48	SCL c	GR SBK	1:1 / VFR 1:1 / FI			.1942 Wetness Cond. S .1943 Depth/.1956 Sapr. -S .1944 Restrictive Hori. -S .1948 Profile Class. PS Profile LTAR 0.35
4	L 4%	0-48	c	SBK	1:1 / F			.1942 Wetness Cond. S .1943 Depth/.1956 Sapr. -S .1944 Restrictive Hori. -S .1948 Profile Class. PS Profile LTAR 0.35

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS
SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.35 gpd/ft²
EVALUATED BY: STEVE HENKEL OTHER(S) PRESENT: BRADY FREEMAN, JERRY HAYES
COMMENTS: