DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 4803 78 2151.
COUNTY: REDACTED

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: MICHAEL BICIO APPLICANT: SAME
ADDRESS: 291 OAK HOLLOW RD, UG 28689 APPLICATION DATE: 12-28-00 DATE EVALUATED: 1-22-00
PROPOSED FACILITY: 3BR House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2.09 ACRES
LOCATION OF SITE: NC 15 TL LINNEY'S TR OAK Hollow, 0.8 MILE ON LEFT PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 18%	0-8	GR SL	VFR SS/P SS/P	MOTTLES < CHROMA 2 AT 30"				PS 0.3
		8-30	SBK C	FI S/P SS/P					
		30-48	SBK SI C	FR SS/P SS/P					
2	L 18%	0-6	GR SCL	VFR SS/P	MOTTLES < CHROMA 2 AT 36"				PS 0.3
		6-36	SBK C	FI S/P					
		36-48	SBK C	FR SS/P					
3	L 15%	0-8	~~GR~~ SCL	VFR SS/P	MOTTLES < CHROMA 2 AT 36"				PS 0.3
		8-36	SBK C	FI S/P					
		36-48	SBK C	FR SS/P					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE / FRENCH DRAIN
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HEDRICK
OTHER(S) PRESENT: MICHAEL BICIO