DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 4803 78 8089
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: KENNETH JOHNSON APPLICANT: SAME
ADDRESS: 805 CALAHAN RD, MOCKSVILLE, NC 27028 APPLICATION DATE: 8-20-99 DATE EVALUATED: 8-27-99
PROPOSED FACILITY: 3BR DWELLING PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.18 ACRES
LOCATION OF SITE: OAK HOLLOW #5 PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	S 0-2%	0-4	GR / SL	VFR / NEXP					PS 0.3
		4-42	SBK / C	FR / NEXP					
		42+	SBK / CL SAPROLITE	FR / NEXP					
2	L 4%	0-4	GR / SL	VFR / NEXP					PS 0.3
		4-48	SBL / C	FR / NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	I	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: KENNETH JOHNSON