## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Haskell Barker DATE 9-21-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N - TL on SR 1598 (Linney Mill Rd) TL into Private Rd before SR 1595 S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Acreage

Character & Porosity of Soil C7B2
Percolation Rate mod
Topography 6-10% Slope
Depth to Water Table mod
Rock or other impervious formations Some Rock



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Jimmy Cothren
Alexander Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 9/26/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold