DEPARTMENT OF ENVIRONMENTAL ...
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: TRADE

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JON SMITHEY APPLICANT: S/HC
ADDRESS: 593 PURTAN ARK RD N WILKESBO APPLICATION DATE: 3-31-99 DATE EVALUATED: 4-12-99
PROPOSED FACILITY: 3BR D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 11.91 ACRES
LOCATION OF SITE: NC 115 N, TL LINNEY'S MILL TR OAK HOLLOW, 0.5 mi L PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	SLIGHT N 4%	0-48	SBK / c cl	FR FI / SLP					PS 0.3
2	SLIGHT N 5%	0-48	SBK / c-cl	FR FI / SLP					PS 0.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): S
EVALUATED BY: S. HODRICK
OTHER(S) PRESENT: EMILY SMITHEY