IREDELL COUNTY HEALTH DEPARTMENT

07106 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Rhyne DATE 6-1-88 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 115 N. To on Mt. View Rd to Stroud Ln Turn - To into Private drive Across from Mt. View Ch. S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Sandy Loam
Percolation Rate Excellent
Topography Rolling
Depth to Water Table 10'
Rock or other impervious formations None

Lot Area Ample

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 400 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Jerry Hartness

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-1-88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold