IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Geo. Hicks (property owner) DATE April 28, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N., T.L. at Central Grocery on 1582, 4th house on Rt _____

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area _____

Character & Porosity of Soil Cecil Clay loam
Percolation Rate none
Topography 2-6% slope to Rt rear
Depth to Water Table 10ft
Rock or other impervious formations none observed



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlie Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: existing house, addition of bathroom inside house

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE April 28, 1977

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold