1234.

36714

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR CRANDELL CASS DATE 4-5-90 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 115 N - 4 mi past Central School - Double wide behind mobile home on left. S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1.22 acres.

Character & Porosity of Soil Prev. Suitable.

Percolation Rate 4 gal/sq. ft.

Topography Slight

Depth to Water Table 60+

Rock or other impervious formations None observed.

____ Basement with Plumbing ____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.


Nitrification Field:

No. of Lines 4

Sq. Ft. 300 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Darren Weaver

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-5-90

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold