DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 4810 72 0482
COUNTY: REBELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CHRIS SLOAN APPLICANT: SAME
ADDRESS: 129 MTN VIEW RD, STVL, 28625 APPLICATION DATE: 2-23-01 DATE EVALUATED: 3-9-01
PROPOSED FACILITY: 3BR House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2 LIMITED
LOCATION OF SITE: MTN. VIEW EST #25, 26, 27 PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	H 10%	0-4	GR SL	FR					PS
		4-20	SBK CL	FR S/P SE,SP	2.5YR 6/8				0.2
		20-48	SBK C	FR ST/SP SE,SP	2.5YR 4/2				w/ FRENCH DRAIN
					U				
2	L 8%	0-22	SBK CL	FR ST/SP SE,SP					PS
		22-48	SBK C	FR ST/SP SE,SP	2.5YR 4/2				0.25
					U				w/F.D.
3	L 8%	0-28	SBK CL	FR ST/SP SE,SP					PS
		28-48	SBK C	FR ST/SP SE,SP					0.25
4	H 10%	0-14	SBK CL	FR ST/SP SE,SP					PS
		14-48	SBK C	FR ST/SP SE,SP	2.5YR 4/2				0.25
					U				w/FD

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HEDRICK
OTHER(S) PRESENT: JIM NELSON, CHRIS SLOAN & WIFE