IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Russell Sloan DATE July 1, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N., just past Central Grocery, T.L. on dirt Rd #1622 T.L. on dirt drive behind 1st brick house on left S. R. No. _____

SUBDIVISION NAME Mobile Home in woods LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area acreage

Character & Porosity of Soil Coastal Clay
Percolation Rate none
Topography 2-6%
Depth to Water Table unk
Rock or other impervious formations none found



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"+
Water Supply: Individual (✓)
Public ( )

Installed by James Hartness

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Lowry DATE 7/1/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold