IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ronald L. Deal DATE 5-2-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N. Trailer on R about ½ mile past Central Gro. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	No Perk Test
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to front
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area Acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 252
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY E. G. Stevenson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 5-2-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold