IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. Builders DATE June 14, '78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N T.L. on SR 1583 T.R. on SR 1584 1st lot on left

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ~2 AC.

Character & Porosity of Soil Cecil clay loam
Percolation Rate —
Topography 2%
Depth to Water Table unk.
Rock or other impervious formations some scattered rock



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 765 Linear Ft. 255
Depth of Stone in Lines 10" ±
Water Supply: Individual (✓)
Public ( )

Installed by Arnie Duncan of Hope Bros.

IMPROVEMENTS PERMIT BY D. R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE June 14, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold