## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J.D. McClelland DATE 8-3-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1.5 Mi. TL on SR 1583 (Lone Valley Rd) TR on SR 1611 Toward Lone Valley Frame House behind 2nd Brick House on left SR. No. 1611


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____ Prov. Suitable

No. Bedrooms 2 No. Bathrooms 1

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | C & C2 |
| Auto. Dishwasher | Yes ( ) | No (✓) | Percolation Rate | 6-10" |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | Slope |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | — |
| | | | Rock or other impervious formations | None |

Lot Area _____



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by James Hartness

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 8/5/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold