HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 15C-A-2A
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MARY F. BLACK OWNER: ✓ AGENT: PHONE: 592-4801
ADDRESS: RT. 2, Box 297-A APPLICATION DATE: 5/24/94 DATE EVALUATED: 5/25/94
STATESVILLE, NC 28677 PROPOSED FACILITY: PLANNED FOR FUTURE 3BR
PROPERTY SIZE: 5 ACRES
LOCATION OF SITE: NC 115 N, TL MTN VIEW RD, TR LOVE VALLEY RD, X-CREEK, 1ST ON (L)
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	FP 0%	0-30	SC	GR	1:1 / VFR	.1942 WETNES CONDITION	42"+ PS
		30-42	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE	S
		42+	MOTTLED			.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.4
2	FP 0%	0-28	SC	GR	1:1 / VFR	.1942 WETNES CONDITION	40"+ PS
		28-40	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE	S
		40+	MOTTLED			.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.4
3	FP 0%	0-24	SC	GR	1:1 / VFR	.1942 WETNESS CONDITION	40"+ PS
		24-40	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE	S
		40+	MOTTLED			.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.4
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.4
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S HEDRICK OTHER(S) PRESENT: MOLLY BLACK
COMMENTS: SYSTEM TO BE INSTALLED NO DEEPER THAN 24"

DRAFT