DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: [illegible]

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JAMES ANGEL APPLICANT: SAME
ADDRESS: 963 FARMINGTON, MOCKSVILLE APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: 2 BR CABIN PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: 1.0 ACRE
LOCATION OF SITE: LOVE VALLEY ROAD NEXT TO PRESS ROAD PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTA
1	L 6%	0-48	SBK / SC	FR / 1:1	—	—	—	—	PS 0.33
2	L 8%	0-48	SBK / SC	FR / 1:1	—	—	—	—	PS 0.33
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	CONV. GRAV	CONV. GRAV
Site LTAR	0.33	0.33

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: JIM ANGEL