HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 150-A-154
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: BETTY REYNOLDS OWNER/AGENT: PHONE: (919) 789-9423
ADDRESS: 202 TAYLOR ST. APPLICATION DATE: 12/8/93 DATE EVALUATED: 12/8/93
MT. AIRY, NC 27030 PROPOSED FACILITY: 1 BR CABIN (EXISTING)
PROPERTY SIZE: LIMITED
LOCATION OF SITE: NC115 N, TL MTN. VIEW RD TR LOVE VALLEY RD, ON (R) POST DOWN HILL
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	N 4-6	0-16	C	SBK	1:1 / FR	.1942 WETNESS CONDITION: S
		16-48	C	ABK	1:1 / FR	.1943/.1955 SAPROLITE: S
						.1944 RESTRICTIVE HORIZON: S
						.1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.35 GPD/FT2
2						.1942 WETNESS CONDITION:
						.1943/.1955 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:
3						.1942 WETNESS CONDITION:
						.1943/.1955 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:
4						.1942 WETNESS CONDITION:
						.1943/.1955 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:
5						.1942 WETNESS CONDITION:
						.1943/.1955 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:

AVAILABLE SPACE (.1945): 3 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT2
OTHER FACTORS(.1946): NONE SYSTEM TYPE: CONV. GRAVITY
EVALUATED BY: STEVE HENDRICK OTHER(S) PRESENT: BETTY REYNOLDS
COMMENTS: PLANNED FOR 2BR

DRAFT