DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 4811 55 1966
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: MARK & DEBORAH CLARK APPLICANT: STAFF
ADDRESS: 153 McGREGOR LANE STATESVILLE 28625 APPLICATION DATE: 9-26-01 DATE EVALUATED: 9-25-01
PROPOSED FACILITY: 2BR H/BMT PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: 2.78 ACRES
LOCATION OF SITE: 153 McGREGOR LANE, LOT # 12 (GRICK) PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	SLIGHT N 162	0-3	GR SL	VFR SEXP					PS
		3-36	WMSBK C	FR S/SP SEXP					0.25
		36-48	WMSBK SAP. MX 3C	FR SS/SP					
2	SLIGHT N 182	0-6	GR SL	VFR SEXP	2.5YR6/2				PS
		6-36	WMSBK C	FR S/SP SEXP					0.25
		36-48	WMSBK SAP. MX 3C	FR SS/SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	INSTALLED S	PS
System Type(s)	II	IV
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: STEVE HEDRICK / RANDY FREEMAN
OTHER(S) PRESENT: MARK CLARK