1577.

IREDELL COUNTY HEALTH DEPARTMENT 31283

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DARRELL JONES DATE 6-8-90 PERMIT NO. ISD-2-C-11.

PHONE: Business _____ Home _____

LOCATION Love Valley Rd. - 21 mt. View Rd. - T. L. on Mitchell Lane - T. R. on 2nd st. then 1st rd. left - then back to 1st house on left

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ P.B. No. _____


House ( ) Mobile Home ( ) Business ( ) Other CAMPER.

No. Bedrooms 1 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )
Lot Area Ample.

Character & Porosity of Soil Poor Suitable.
Percolation Rate _____
Topography _____
Depth to Water Table 18+
Rock or other impervious formations scattered rock.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 540 Linear Ft. 180
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Andy Jones

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Glenn Faulkner

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-8-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold