IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dwight Younger DATE 10-17-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N T. L. on S.R. 1598 (Jimmy Mill Rd.) beside 1st brick house on left past Taybe Springs Ch. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )

Lot Area acreage

Character & Porosity of Soil Cecil clay loam
Percolation Rate —
Topography 2%
Depth to Water Table sink.
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 300
Depth of Stone in Lines 10"+
Water Supply: Individual ( )
Public ( )
Spring

Installed by Glenn Haynes
from N. Wilkesboro

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 10-17-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold