DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4813675810 (PT)

OWNER: MILDRED F HURLBUT APPLICANT: SAME
ADDRESS: 362 SANDBURG RD, UG, NC APPLICATION DATE: 10.15.99 DATE EVALUATED: 11-10-99
PROPOSED FACILITY: 3BR D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 10.83 ACRES
LOCATION OF SITE: 362 SANDBURG ROAD PROPERTY RECORDED: ____
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☑ Spring ☐ Other ____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 6%	0-6	GR / SCL	VFR / NEXP					PS 0.25 .1956
		6-30	SBK / CL	FR SS/SP/NEXP					
		30-48	SBK / SC	FR SS/SP/NEXP	7.5YR 5/1				
2	L 4%	0-4	GR / SCL	VFR / NEXP					PS 0.25 .1956
		4-28	SBK / CL	FR SS/SP/NEXP					
		28-48	SBK / SC	FR SS/SP/NEXP	7.5YR 5/1				
3	L 6%	0-6	GR SCL	VFR / NEXP					PS 0.25 .1956
		6-32	SBK CL	FR SS/SP/NEXP					
		32-48	SBK SC	FR SS/SP/NEXP	7.5YR 5/1				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	IV
Site LTAR	0.25	0.125 (LPP)

OTHER FACTORS (.1946): .1956 APPLIES (DRAINAGE)
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: JEFF & MILDRED HURLBUT