IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. A. Williams DATE 29 July 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy 115 N past 901. T. L on dirt Rd 1/4 mi. T. L at 1st driving - Thru L end of road S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	None
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Hilly
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	0
			Rock or other impervious formations	0

Lot Area acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Jones Hartness

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY W. M. Howard DATE 29 July 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold