IREDELL COUNTY HEALTH DEPARTMENT

Buyer
Ray Coltman

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Merrill Tank Const. Co. DATE 6 Nov 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N. past Cross Store - T.L. just past store on RD # 1608 - 1st house on left S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Clay Loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	none
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight slope to rear of house
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	ok
			Rock or other impervious formations	ok

Lot Area 1 acre



Plot of System RD # 1608

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 660 Linear Ft. 240
Depth of Stone in Lines 10" plus
Water Supply: Individual (✓)
Public ( )

Installed by Merrill Tank Const. Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: very good soil.

CERTIFICATE OF COMPLETION BY Will Howard DATE 6 Nov 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold