# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR R. L. Calloway DATE 30 Sept 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy 115 N pvmnt Hy 801 appx 1½ mile - Ly House on Left before Corner Store.

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) |
| Auto. Dishwasher | Yes ( ) | No (✓) |
| Auto. Wash. Machine | Yes (✓) | No ( ) |
| Site Suitable | Yes (✓) | No ( ) |

Lot Area acre


Character & Porosity of Soil Red Clay loam

Percolation Rate more

Topography 2-6 % Slopes

Depth to Water Table ok

Rock or other impervious formations ok




Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public ( )

Spring behind house

Installed by James Hartness

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Neill Stewart DATE 30 Sept 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold