01677 - Brenda Mohler 204954

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jim Mohler DATE 8-16-84 PERMIT NO.

PHONE: Business Home

LOCATION 115 N. TR on SR 1902 Th on SR 1900 2nd Driveway on left Behind Mobile Home

SUBDIVISION NAME S. R. No.


LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Clay-Red Brown
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate 3 Gal/Ft/Day
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2-6% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10'
Lot Area 1 Acre			Rock or other impervious formations Fractured Rock

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Jimmy Cathren

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

Location of the proposed 40'X20' BLDG addition does not appear to impact the existing on-site septic system or well.**NOTE:

IMPROVEMENTS PERMIT BY REHS Date: 08/04/84

ICHD-Environmental Health Division

COMMENTS:

CERTIFICATE OF COMPLETION BY

EXISTING SYSTEM CHECKED BY: DATE 8/16/84

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold