IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Snow Creek Masonic Lodge DATE 11/6/75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N. go 1 mile past Central Sch., 1st paved Rd on Rt (1898) 1st ½ Mtg. on left. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Lodge

No Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Red Clay Loam
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	Poor
Auto. Wash. Machine	Yes ( )	No ( )	Topography	slope to front
Site Suitable	Yes ( )	No ( )	Depth to Water Table	unknown
			Rock or other impervious formations	none found

Lot Area 1½ - 2 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 350

Depth of Stone in Lines 10"

Water Supply: Individual (+)

Public ( )

Installed by Bobby Beattie

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 11/6/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold