I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR ROGER McLELLAND DATE 4-21-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115N – T.R. on Dotsson Rd. – house on R before Grant Rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil		
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	EXISTING	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography		
Site Suitable	Yes (✓)	No ( )	Depth to Water Table		
			Rock or other impervious formations		

Lot Area Ample

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank EXISTING Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Dennis Gallihar

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Glenn Hoff Jr.

COMMENTS: Mobile home to be removed from property. Old lines abandoned from existing tank.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-21-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold