Lot 11
George Mahaffy

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Horst Raddle DATE 14 June 76 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Hwy 115 N past Central Armory to Rd 1858 on Rt. go to Rd 1852 on left. go to end of road. Driving to left but left road appx 4 mi. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil clay loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	one
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Very steep
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	ok
Lot Area average			Rock or other impervious formations	Patio rock



Plot of System well

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Luby

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [illegible] DATE 14 June X

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold