DIVISION OF ENVIRONMENTAL HEALTH

COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Tony Hinson OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ.	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Nose slope 10%	0 to 10	L GR		PS	36" Rock	PS	PS	.35
		10 to 36	SCL W SBK	NEAP FR					
		36	Rock + Sap						
2	Nose slope 10%	0 to 8"	L GR		PS	42"	PS	PS	.35
		8 to 28	SCL W SBK	NEAP FR					
		28 to 42	Clay Sap.	NEAP VFR					
		42"+	Sap Rock						
3	Linear 12%	0 to 8	L GR		PS	PS	PS	PS	.3
		8 to 48	SC SBK	SEAP Fi to FR					
4									
5									

SUITABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .33
EVALUATED BY: P.C. Moore OTHER(S) PRESENT: Tony Hinson
COMMENTS: