IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

12428 PART OF

OWNER OR CONTRACTOR ALBERTA & WENDY WELBORN DATE 2/15/91 PERMIT NO. 14N-A-11A

PHONE: Business _____ Home _____

LOCATION NC 115 N, TL ISAAC RD, ON (L) BEHIND CHURCH

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 27,800 ² FT

Character & Porosity of Soil DS
Percolation Rate .4 GPD / FT²
Topography 10-12 % LS
Depth to Water Table 2 4'
Rock or other impervious formations SCATTERED ROCK

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual (✓) WELL
Public ( )

Installed by J.C.'s BACKHOE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 2/15/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold