DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 4821391555
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dennis Floyd
ADDRESS: 145 Cedarwoody Rd.
PROPOSED FACILITY: 3 BR Repair PROPOSED DESIGN FLOW (.1949): 360 gpd
LOCATION OF SITE: 145 Cedarwoody Rd.
WATER SUPPLY: • Private • Public • Well • Spring • Other N/A
EVALUATION METHOD: • Auger Boring • Pit • Cut TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

APPLICATION DATE 3-14-14
DATE EVALUATED: 3-26-14
PROPERTY SIZE: 1.683 acres
PROPERTY RECORDED: Yes

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	5% L	0-14	SCL SBK	Fr Mod SE	+42"	42"	+42"	42"	PS 0.3
		14-34	C SBK	Fi Mod SE					
		34-42	CL WSBK	Fr Mod SE					
		42"	Rock						
2	8% L	0-7	SCL SBK	Fr Mod SE	+48"	+48"	+48"	+48"	PS 0.3
		7-36	C SBK	Fi Mod SE					
		36-48	CL WSBK	Fr Mod SE					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		PS
System Type(s)		ATT
Site LTAR		0.3

OTHER FACTORS (.1946): N/A
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Justin Henderson
OTHER(S) PRESENT: N/A

COMMENTS: N/A