IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Lee Jones DATE 10-1-73 PERMIT NO. _____

PHONE: Business _____ Home 872-5775

LOCATION 115 N. Aberm Central Fire Dist. TR on Rd #1869 Go About 1 Mile. Trailer on R. S. R. No. 1569

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Good
Percolation Rate Per Perk Test Rec.
Topography Level
Depth to Water Table Low
Rock or other impervious formations None

Lot Area 4 Acres



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 616 Linear Ft. 231
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Herman Gibson

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Trailer on H.H Yoho Property. Water from Mr Yoho's Well. Dishwasher has been deleted from Original Layout. No Dishwasher.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 10-11-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold