DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bobby Burgess Jr.
ADDRESS: 308 Rupard Rd
APPLICANT: Sam
PROPOSED FACILITY: 1 SFDwMH
APPLICATION DATE: 7/22/16
DATE EVALUATED: 8/12/16
LOCATION OF SITE: RUPARD RD OFF 15N
PROPOSED DESIGN FLOW (.1949): 240
PROPERTY SIZE: 23.6
PROPERTY RECORDED: Y
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 7-16%	0-4	GR - L vcl	FR - NEX -	S				
		5-10	MOD SBK cl L SBK	FR NEX - FR	S				
		11-17	S SBK cl SBK	SS - NEX - FR	S				
		18-32	SBK scl Sm SBK	SS - NEX - FR	S				.25
		34-	Rock - FLOATERS						
2		0-5	GR - SL	VFR - NEX - NS	S				
		6-14	MS SBK - cl	SEXP - FR - SS	PS				.25
		15-26	M SBK - cl	SEXP FR - SS	PS				.3
		27-35	Rock F SBK - GR	NEXP - FR NS	S				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	III	III
Site LTAR	.25	.25

OTHER FACTORS (.1946): FLOATERS BELOW 32" THROUGHOUT
SITE CLASSIFICATION (.1948): NOTHING CONSOLIDATED FOUND WITH AUGER.
EVALUATED BY: Jeff Spears
OTHER(S) PRESENT: B Burgess