IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard D. Abernethy DATE 19 Jan 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy 115 N to Conrad Rd 1861 - 4/10 to SR 1867 on Left. 1/2 appx 100' to Farm on Right. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sand Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	None
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to rear of property
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'
			Rock or other impervious formations	4'

Lot Area 1 acre



Plot of System SR 1867

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 615 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by [illegible]

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY WM Stevens DATE 15 Jan 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold