37952

IREDELL COUNTY HEALTH DEPARTMENT

11807 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR FRANK B. HALL DATE 5/22/90 PERMIT NO. ISE-455

PHONE: Business 592-4378 Home

LOCATION NC 115 N, CROSS ROCKY CREEK 1ST DRIVE on (R) S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other


No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil .4 CLAYEY
Percolation Rate 6-10%
Topography ≤4%
Depth to Water Table
Rock or other impervious formations SCATTERED ROCK

Lot Area 16.86

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by VERNON BACKMEN & SONS

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY STEVE HEDRICK / GLENN FOX, JR

COMMENTS:

CERTIFICATE OF COMPLETION BY STEVE HEDRICK / GLENN FOX, JR DATE 5/22/90

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold