IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Allen Lunsford DATE 3-11-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N' Past Hwy 901. White House on R Just before Texaco Serv Sta. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area Acreage

Character & Porosity of Soil _____
Percolation Rate ADDITION TO PRESENT HOUSE
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Old Tank
Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Calvin Johnson

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold