HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 15-J-A-10 (PACT)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: EARL L. ADDAIR OWNER: ✓ AGENT: PHONE: 838-0684
ADDRESS: P.O BOX 82 APPLICATION DATE: 1/6/94 DATE EVALUATED: 1/6/94
AVONDALE, WV PROPOSED FACILITY: 3BR D/W MH
24811 PROPERTY SIZE: 2.25 AC
LOCATION OF SITE: NC 115 N TR FLETCHER RD ~ 1 1/2 MILE ON (L)
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	N 6%	0-8	SC	GR	1:1 / FR	.1942 WETNES CONDITION S
		8-38	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE S
		38-48	SC	SBK	1:1 / FR	.1944 RESTRICTIVE HORIZON S
					/	.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
2	L 6%	0-8	SC	GR	1:1 / FR	.1942 WETNES CONDITION S
		8-48	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: SCOTT ADDAIR
COMMENTS:

DRAFT