HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 15J-A-10
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JAMES E. PADGETT OWNER: ✓ AGENT: PHONE: 871-2993
ADDRESS: 1414 E. BROAD ST. APPLICATION DATE: DATE EVALUATED:
STVL, NC 28677 PROPOSED FACILITY: 4BR DW MH
PROPERTY SIZE: 2.25 AC
LOCATION OF SITE: NC 115 N, TR FLETCHER RD, ON (L) JUST BEFORE 2ND RD.
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 4%	0-6	SCL	GR	1:1 / FR	.1942 WETNES CONDITION S
		6-40	C	ABK	1:1 / FR	.1943/.1956 SAPROLITE PS (40")
		40-48	SAPRO	SANDY-GR	FR	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
2	L 6%	0-9	SCL	GR	1:1 / FR	.1942 WETNES CONDITION S
		9-36	~~C~~	~~SANDY-GR~~ ABK	1:1 / FR	.1943/.1956 SAPROLITE PS (36")
		36-48	SAPRO	SANDY-GR	FR	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) 3 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: HOMER BALL / JAMES E. PADGETT
COMMENTS:

DRAFT