7327

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Hathcock DATE 6-26-85 PERMIT NO. B 6

PHONE: Business _____ Home _____

LOCATION N. Chipley Ford Rd

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Loam to Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	See attached
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Level to Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'
Lot Area _____			Rock or other impervious formations	Encountered

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plat of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 220 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by H. L. Hendrix Sons

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D. Wren

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 6/28/85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold