DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of
PROPERTY ID #: ___
COUNTY: CEDAR

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4830 85 3581

OWNER: FLEETWOOD HOMES APPLICANT: SAME
ADDRESS: 1270 NORTHSIDE DRIVE, SVL, 28625 APPLICATION DATE: 1-25-02 DATE EVALUATED: 2-12-02
PROPOSED FACILITY: 4BR DW MH PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: US 21 N, TL JENNINGS, R FRIENDSHIP, ON (L) AT PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other GOVERNMENT
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	SLIGHT H 6%	0-10	GR SL	VFR SEXP					PS 0.3
		10-22	SBK C	FI SS/SP SEXP					
		22-48	SBK C	FR SEXP					
2	SLIGHT H 7%	0-12	GR SCL	VFR SEXP					PS 0.3
		12-24	SBK C	FI SS/SP SEXP					
		24-48	SBK C	FR SEXP					
3	L 7%	0-8	GR SCL	VFR SEXP					PS 0.3
		8-24	SBK C	FI SS/SP SEXP					
		24-48	SBK C	FR SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: DAVE LICHAS/FLEETWOOD