DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #:
COUNTY: REBELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4841 02 7429

OWNER: ROBERT E. ALMOND APPLICANT: SAME
ADDRESS: 157 CRAFFORD STABLE RD, CLIN 28626 APPLICATION DATE: 6-5-01 DATE EVALUATED: 7-6-01
PROPOSED FACILITY: 3BRD/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: LIMITED
LOCATION OF SITE: CURRENT ROAD, 0.2 mi FROM EVERGREEN SPRINGS ROAD PROPERTY RECORDED:
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 8%	0-20	SBK CL	FR SEXP					PS 0.35
		20-48	SBK SC	FR SEXP					
2	N 8%	0-24	SBK CL	FR SEXP					PS 0.35
		24-48	SBK SC	VFR SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.35	0.35

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: D. HEDRICK
OTHER(S) PRESENT: JOHN CASLEY, ROBERT ALMOND