Permit #178073

41286

1:00

A-1 BACKHOE

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

13528

OWNER OR CONTRACTOR JOHN W. REICH, JR DATE 3/[illegible]/92 PERMIT NO. 15F-A-29

PHONE: Business _____ Home _____

LOCATION NC 115 N, TR PROSPECT CH. ROAD TL AYCOCK ROAD, ~1/2 MILE ON (R), LONG DRIVE TO WOODED AREA S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area AMPLE,

Character & Porosity of Soil PS


Percolation Rate .35 GPD / FT2

Topography 6-8% SS

Depth to Water Table >4'

Rock or other impervious formations SOME ROCK

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

approx 2640' @ road

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"

Water Supply: Individual (✓) WELL
Public ( )

Installed by A-1 Backhoeders.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-2-92

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

Location of the proposed pole barn 30' x 50' addition does not appear to impact the existing on-site septic system.NOTE:**

James [illegible] REHS

Date: 4-23-13

ICHD-Environmental Health Division