EDELL COUNTY HEALTH DEPARTMENT — STATESVILLE 704-878-5305 — MOORESVILLE 704-664-5281

PROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

565271

PERTY DESCRIPTION NO. 17022 DATE 9/14/93 TAX MAP NO. 15A-A-6

ER OR CONTRACTOR BRENT WEISNER PHONE: Business 878-3012 Home 871-1516

ESS 1009 HUNTER ST. STATESVILLE NC 28677

ON NC 115 N. TR SPRINGS RD. TL MYERS MILL RD 1ST DRIVE ON (L)

ISION BLOCK / SECTION LOT LOT AREA 1.31 ACRES SITE CLASS PS L.T.A.R. 0.40 GPD/FT2

Supply: Individual Community Public WELL TO BE LOCATED

Tank 1000 Gallons: SIB 794 Date 6-22-95

Tank Gallons: PT Date

Trench Proj. No. Feet 1 Square Feet 900 Linear Feet 300

Lines 3 Trench Width 36" Trench Depth 18-36" Gravel Depth 12"

Sys. System Repair System Type C

Sys. Description CONV. GRAVITY

Subsoil Description CONV. GRAVITY

Soil Evaluation Requirement Required: Yes No

House/Mobile Home TEMP No. Bedrooms 3 Garbage Disposal: Yes No

No. Bathrooms 2½ Auto. Dishwasher: Yes No

Business No. Employees Auto. Washing Machine: Yes No

Other PLANNED FOR FUTURE HOUSE Other

Slab Crawl Space Basement w/plumbing Basement w/o plumbing

Comments (1) KEEP SYSTEM MINIMUM 5' FROM MH & FUTURE HOUSE SITE 10' FROM PROPERTY LINE, 100' FROM WELL (2) INSTALL LINES ON CONTOUR NO DEEPER THAN 36" 9' APART ON CENTER (3) MH TO BE REMOVED UPON OCCUPANCY OF HOUSE.

INITIAL SITE SKETCH

OLD FIELD TERRACE

TEMPORARY DRIVE

SEPTIC TANK

3 X 100'

3 X 100'

3 X 100'

LONG DRIVEWAY ~ 350'

FUTURE HOUSE

POTENTIAL WELL SITE

AS BUILT SKETCH

3 X 100'

3 X 100'

3 X 100'

DROP

SEPTIC TANK

HOUSE

LAND DROPS OFF

WELL

MYERS MILL ROAD

Permit may be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made to the installation of the system. Permit is valid for 60 months from date of issuance.

Issued Permit by: STEVE HEDRICK date 9/14/93

System Inspected by: date

Installed by: A-1 BACKHOE

Certificate of Completion by: STEVE HEDRICK date 9-12-95

Operation Permit by: date

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD

The proposed Garage addition does not appear to impact the existing septic system.

**NOTE:

R.S.

Date: 6-2-09

ICHD-Environmental Health Division

DRAFT

JAN. 2, 1989 0:24