HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: IRF-A-78
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: DAVID PREVETTE OWNER: ✓ AGENT: PHONE: 592-2112
ADDRESS: 135 PROSPECT RD APPLICATION DATE: 5/13/94 DATE EVALUATED: 5/13/94
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 2 ACRES
LOCATION OF SITE: NC 115 N, TR PROSPECT RD, ON (R) JUST BEFORE MYERS MILL RD
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 4%	0-30	C	ABK	1:1 / FI	.1942 WETNES CONDITION S
		30-48	C/SAP	WSBK	1:1 / FR	.1943/.1956 SAPROLITE MIX AT 30"
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
2	L 4%	0-34	C	ABK	1:1 / FI	.1942 WETNES CONDITION S
		34-48	C/SAP	WSBK	1:1 / FR	.1943/.1956 SAPROLITE MIX AT 34"
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONVENTIONAL GRAVITY
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: DAVID PREVETTE
COMMENTS:

DRAFT

0019 82