DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH, ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH

Sheet 1 of 1
PROPERTY ID #: 4832341782
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM
(Complete all fields in full)

OWNER: Clay Lunsford
ADDRESS: 781 Myers Mill Rd
PROPOSED FACILITY: SFD
PROPOSED DESIGN FLOW (.1949): 240
LOCATION OF SITE: Intersection of Prospect & Myers Mill
WATER SUPPLY: ☒ Private ☐ Public ☑ Well ☐ Spring ☐ Other N/A
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut

APPLICATION DATE 12-2-14
DATE EVALUATED: 12-8-14
PROPERTY SIZE: 0.922ac
PROPERTY RECORDED: Yes
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 7%	0-6	GR SCL	fr SE	PS	PS	N/A	N/A	PS .3
		6-26	SBK C	fi SE					
		26-48	WA BK BC	Fi/F SE					
			Few rock inclusions 26"-48"						
2	L 5%	0-9	GR SCL	fr SE	PS	PS	N/A	N/A	PS .3
		9-40	SBK C	fi SE					
		40-48	WA BK BC	Fi/F SE					
			Few rock inclusions 9"-20"						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		PS
System Type(s)		II
Site LTAR		.3

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: H. Snow
OTHER(S) PRESENT:

COMMENTS: