DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Rachel & Tom Arrington APPLICANT: _____
ADDRESS: 831 myers mill Rd APPLICATION DATE: _____ DATE EVALUATED: 6-15-00
PROPOSED FACILITY: Single Family PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 6 acres
LOCATION OF SITE: 290 W TL Myers mill TR Morgan Ford. 2nd PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	290 linear	0to42	SL GR	loose NEAP	Bluish clay	H2" S	5	5	5 .6
		H2	C massive	Fi EAP					
2	290 linear	0to48	SL GR	loose NEAP	Sandy	48" S	5	5	5 .8
3	290 linear	0to36	SL GR	loose NEAP	Brownish	48" S	5	5	5 .6
		36to48	Silty clay B loam	VFR NEAP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	conv. Gravity	11
Site LTAR	.6	.6

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): Suitable
EVALUATED BY: R. C. moore
OTHER(S) PRESENT: Tom Arrington