DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: [redacted] 16F-A-2
PROPERTY RECORDED: ___
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: ARNOLD JAMES HENDRIX OWNER: ___ AGENT: ✓ PHONE: 539-5295
ADDRESS: P.O. BOX 94 APPLICATION DATE: 4/18/95 DATE EVALUATED: 4/18/95
MG, NC 28689 PROPOSED FACILITY: 3 BR HOUSE
PROPERTY SIZE: 13.34 ACRES
LOCATION OF SITE: US 21 N TL JENNINGS, TL TRUMPET BRANCH ON (R) PAST GOFORTH RD
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ✓

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	N 16%	0-30	SBK / C	1:1 / FI	S	S	PS	PS	0.35
		30-40	WSBK / SC	1:1 / FR					
		40+	SAPROLITE (SAND)						
2	N 14%	0-32	SBK / C	1:1 / FI	S	S	PS	PS	0.35
		32-40	WSBK / SC	1:1 / FR					
		40+	SANDY SAPROLITE						
3									
4									
5									

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35
EVALUATED BY: S. HENDRIX OTHER(S) PRESENT: EDWARD STEINMETZ
COMMENTS: SYSTEM INSTALLED 28-30"

000632