IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Shirley Ford Riley Farm DATE 20 Oct 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jerusalem Rd to Old 1861. Left Rd 1858 on right. Left track on left. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sand Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	more
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	nil
			Rock or other impervious formations	nil

Lot Area acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

well on farm

Installed by Ellis Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: Second tracks to be used for storage only. not used on dwelling

CERTIFICATE OF COMPLETION BY W M Tennant DATE 20 Oct 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold