HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 169-2-A-1
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MILLARD TATE HIOTT, JR OWNER: ✓ AGENT: PHONE: 872-0986
ADDRESS: RT. 17, BOX 163 APPLICATION DATE: 7/18/94 DATE EVALUATED: 7/18/94
STVL, NC 28677 PROPOSED FACILITY: 4 BR MOD HOME W/ BASEMENT
PROPERTY SIZE: 10 ACRES
LOCATION OF SITE: US 21 N, TL JENNINGS RD, TL EUPEPTIC SPRINGS RD, 1.0 MILE ON (L)
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit ✓ Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 2-9	0-18	SCL	GR	1:1/VFR	.1942 WETNES CONDITION 5
		18-48	C	SBK	1:1/FI	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
2	L 2-9	0-20	SCL	GR	1:1/VFR	.1942 WETNES CONDITION 5
		20-48	C	SBK	1:1/FI	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MILLARD HIOTT, JR, JOAN MENSCER, GLEN GATES
COMMENTS:

DRAFT

0006711