HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: T5F-A-12
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RACHEL ARRINGTON OWNER: / AGENT: PHONE: 592-7464
ADDRESS: R.1, Box 200-A APPLICATION DATE: 4/19/94 DATE EVALUATED: 4/19/94
OLIN, NC 28660 PROPOSED FACILITY: 2BR MH
PROPERTY SIZE: ~1 ACRE
LOCATION OF SITE: NC 115 N, TR PROSPECT, TL MYERS MILL, TL MORGAN FORD, 1st on L
WATER SUPPLY: On-Site Well / Comm. Well Public / Other EVAL. METHOD: Auger Boring / Pit Cut

past bridge

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	FP 0-2%	0-28	SCL	GR	1:1 / FR	.1942 WETNES CONDITION	S
		28-48	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT²
2	FP 0-2%	0-24	SCL	GR	1:1 / FR	.1942 WETNES CONDITION	S
		24-48	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT²
3						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: TOM ARRINGTON
COMMENTS:

DRAFT