08003

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

DATE 3-7-88 PERMIT NO. _____

OWNER OR CONTRACTOR WESLEY ROBINSON

PHONE: Business _____ Home _____

LOCATION I-77 N-T.L. on Hwy 901-T.L. on Myers Mill Rd-1st driveway on (R).

S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

SUBDIVISION NAME _____

House ( ) Mobile Home (✓) Business ( ) Other _____

DOUBLEWIDE

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable ✓

Lot Area 5 acres

Character & Porosity of Soil Prev. Suitable

Percolation Rate 1"-30 min/2 ft.

Topography 2-6% Ut

Depth to Water Table none observed.

Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:


No. of Lines 2

Sq. Ft. 120 Lineal Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )



Plot of System

Installed by James Hartness

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Spring to be used for water supply.

DATE 3-7-88

CERTIFICATE OF COMPLETION BY Steve Brown DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Insp...

Location of the proposed Utility Building addition does not appear to impact the existing on-site septic system.**NOTE: Keep NEW 5' from system

Justin Henderson REHS

Date: 5-17-12

ICHD-Environmental Health Division